

Building Renewal Grant Application

Initial Submission Date: 7/29/2013 2:33:51 PM

Application ID: 646

Resubmittal Date: 7/31/2013 8:42:53 AM

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Phoenix Elementary District

Superintendent: Dr. Myriam Roa

Contact Person: Terry Crosier

Contact Phone Number: 602-257-2809

Contact Email: Terry.crosier@phxschools.org

School Site: Kenilworth Elementary School

Buildings: 9999 School Wide

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

Cooling tower shaft bearing failed and scored the fan shaft.

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Amount of Local funds planned for this project	\$9,361.71

Please outline any associated insurance coverage.

This equipment is 4 years old and is normally only covered by warrentee for 1 year. We called the vendor and verified that it was not covered. There is no issurance claim against this equipment.

Liaison: Cruse

pcruse@azsfb.gov

602-364-1193

Superintendent Printed Name

Superintendent Signature

Date